

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

Product	Terminal blocks for copper conductors
Name and address of the applicant	Weidmüller Interface GmbH & Co. KG Klingenbergrasse 16, 32758 Detmold Germany
Name and address of the manufacturer	Weidmüller Interface GmbH & Co. KG Klingenbergrasse 16, 32758 Detmold Germany
Name and address of the factory	<input checked="" type="checkbox"/> Additional information on page 2 Weidmüller Interface GmbH & Co. KG Klingenbergrasse 16, 32758 Detmold Germany
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	1000 Vac / 1500 Vdc, 8 kV / 10 kV, 35 mm <sup>2</sup> , 125 A (A2C 35, A2C 35-DM) 35 mm <sup>2</sup> (A2C 35 PE)
Trademark (if any)	Weidmüller
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	A2C 35, A2C 35 PE and A2C 35-DM
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60947-7-1:2009, IEC 60947-7-2:2009
As shown in the Test Report Ref. No. which forms part of this Certificate	2248672.54 and 2248672.55

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands  


IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## Additional factory

Weidmüller Interface

Romania S. R. L.

Strada 66

437345 Tautii Magheraus

Romania

Weidmüller Interface (Suzhou) Co. Ltd.

No. 58 Shilin Road

215151 Suzhou

China

EWE s.r.o.

Trebovska 570

562 03 Usti Nad Orlici,

Czech Republic

Weidmuller Lanskroun, s.r.o.

Dobrovskeho 1115

56301 Lanskroun

Czech Republic

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.

Meander 1051, NL-6825 MJ Arnhem, Netherlands

 DEKRA

