

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Test disconnect terminal blocks for copper conductors
Name and address of the applicant	Weidmüller Interface GmbH & Co. KG Klingenbergrasse 16 / 26, 32758 Detmold Germany
Name and address of the manufacturer	Weidmüller Interface GmbH & Co. KG Klingenbergrasse 16 / 26, 32758 Detmold Germany
Name and address of the factory	<input checked="" type="checkbox"/> Additional information on page 2 Weidmüller Interface GmbH & Co. KG Klingenbergrasse 16 / 26, 32758 Detmold Germany
Ratings and principal characteristics	1-pole terminal block with 1 screwless-type and 1 screw-type clamping units Rated cross-section 6 mm ² Ui 500 V, Uimp 6 kV, Ith 30 A
Trademark (if any)	Weidmüller
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	HTTB 6
Additional information (if necessary may also be reported on page 2)	<input type="checkbox"/> Additional information on page 2 The terminal block is tested according to IEC 60947-7-1 Annex D: Additional requirements for test disconnect terminal blocks.
A sample of the product was tested and found to be in conformity with	IEC 60947-7-1:2009
As shown in the Test Report Ref. No. which forms part of this Certificate	2253691.52

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

Additional factory

Weidmüller Interface Romania S. R. L.
Strada 66, 437345 Tautii Magheraus
Romania

EWE s.r.o.
Trebovska 570, 562 03 Usti Nad Orlici
Czech Republic

Weidmüller Interface (Suzhou) Co. Ltd.
No. 58 Shilin Road, 215151 Suzhou
China

Weidmuller Lanskroun, s.r.o.
Dobrovskeho 1115, 56301 Lanskroun
Czech Republic

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands

