

Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

Manufacturer **Weidmüller Interface GmbH & Co. KG**

Address Klingenbergsstr. 26, Detmold, 32758, Germany

Place of Production Weidmüller Interface Romania S.R.L.

Strada 66 Nr. 8, Tautii Magheraus, 437345, Romania

Type Terminals/Insulators

Description Terminal blocks for mounting rails TS35
Insulation material: Wellamid in all colours

Trade Name WPE 2,5N; WPE 1,5/ZZ; WPE 2,5/1,5/ZR

Application Marine, offshore and industrial applications for use in environmental categories ENV1, ENV2, ENV3 and ENV4 as defined in Lloyd's Register's Type Approval System, Test Specification Number 1-1990, Print Edition 2.

Specified Standard EN 60947-7-2 : 2010
UL 94 6th Ed. March 2013

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Thorsten Wolff

Engineering - Senior Specialist to Lloyd's Register EMEA
A member of the Lloyd's Register group

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



Type Approval Certificate

Ratings	Type	Voltage	mm ²	AWG
	WPE 2.5N	500V AC	2.5	14
	WPE 1.5/ZZ	500V AC	2.5	14
	WPE 2.5/1.5/ZR	500V AC	4.0	14

This certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid Certificate.

Previous Version: 93/20003 (E5)

The Design Appraisal Document HPC1862069-23/TW and its supplementary Type Approval Terms and Conditions form part of this Certificate.

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.