

INSTALLATION INSTRUCTIONS
& CONDITIONS FOR SAFE USE

II 2 GD

Ex eb IIC Gb

Modular TERMINAL Blocks: Z- Series**DEMKO 16 ATEX 1729 U****IECEX ULD 16.0025U****Notified Body No. of Ex - QA: 0344****Label print on package unit: 0344****UL21UKEX2118U****Approved Body No. of UK Ex - QA: xxxx****(see product marking)**

Standards:

EN IEC 60079-0:2018 and EN IEC 60079-7:2015 A1:2018

IEC 60079-0: 7th Edition and IEC 60079-7: 5.1th Edition

Modular Terminal Blocks: ZDK/ZDK PE

Version:	ZDK 2.5*	Order No 1674300000
----------	----------	------------------------

in conjunction with:	ZDK 2.5 PE	Order No 1690000000
----------------------	------------	------------------------

Accessories:	Type	Order No
end plate	ZAP/TW ZDK2.5*	1674730000
end bracket	ZEW 35*	9540000000
Terminal rail	TS 35/... acc.to DIN EN 60715	

Cross-connection	Plugable*	Order No
	ZQV 2.5/2	1608860000
	ZQV 2.5/3	1608870000
	ZQV 2.5/4	1608880000
	ZQV 2.5/5	1608890000
	ZQV 2.5/6	1608900000
	ZQV 2.5/7	1608910000
	ZQV 2.5/8	1608920000
	ZQV 2.5/9	1608930000
	ZQV 2.5/10	1608940000

Insulation material:

- Type
- Tracking resistance (A) to IEC 60112
- Flammability class to UL 94

Wemid
CTI ≥ 600
V0

- | | |
|-------------------------------|--|
| - Operating temperature range | -60°C...+110°C (insulating material limit) |
| - Ambient temperature range | -60°C...+40°C (for T6 applications) |
| - Ambient temperature range | -60°C...+55°C (for T5 applications) |
| - Ambient temperature range | -60°C...+70°C (for T4 applications) |


* in all colours

Technical data according to IEC/EN 60079-7 (increased safety "eb"):


	ZDK 2.5	ZDK 2.5 PE
- Rated voltage	440 V	
- Rated current	20 A / ΔT 40 K	
- Temperature rise with rated current	34,4 K / 20 A	
- Rated current with ZQV	20 A / ΔT 40 K	
- Contact resistance top level with rated conductor, 2,5 mm ²	0,6 m Ω	
- Contact resistance bot level with rated conductor, 2,5 mm ²	1,0 m Ω	
- Rated conductor cross section	2,5 mm ²	2,5 mm ²
- Conductor cross section solid	0,5 - 2,5 mm ²	0,5 - 2,5 mm ²
- Conductor cross section stranded	0,5 - 2,5 mm ²	0,5 - 2,5 mm ²
- Conductor cross section flexible	0,5 - 2,5 mm ²	0,5 - 2,5 mm ²
- cross section, American Wire Gauge	26 - 14 AWG	26 - 14 AWG
- Stripping length	10 mm	10 mm

IECEx / ATEX / UKCA Terminal and Cross-Connector Arrangements:


Max voltage data according to IEC/EN 60079-7 in conjunction with protective earth terminal blocks of the ZDK PE-Series, (increased safety "eb"):

Application Case**A - Continuos**


352 V




352 V

C - Adjacent - separated by a end plate


352 V



352 V

D - Intermediate - bridging one or more unconnected terminals (e.g. every 3rd terminal)

275 V

E - Next to a protective conductor terminal (earth) without a end plate

352 V

Information for further cross-connector arrangements will be provided on request.

Note:

If smaller cross sections than the rated cross section are used, the belonging lower current has to be laid down in the IECEX/EC-Type Examination Certificate of the complete apparatus.

Mounting instructions:

The Feed-through terminals and PE terminals of the ZDK-series are suitable for application in enclosures in atmospheres with flammable gases or combustible dust. For use in flammable gases these enclosures must satisfy the requirements according to IEC/EN60079-0 and IEC/EN60079-7. For use in combustible dust these enclosures must satisfy the requirements according to IEC/EN60079-0 and IEC/EN60079-31.

Regarding the use of accessories the instructions of the manufacturer must be followed.

Schedule of Limitations:

The Feed-through terminals and PE terminals of the ZDK-series are suitable for use in enclosures in atmospheres with flammable gases or combustible dust. For flammable gases these enclosures must satisfy the requirements according to IEC/EN 60079-0 and IEC/EN 60079-7. For combustible dust the enclosure must satisfy the requirements according to IEC/EN 60079-0 and IEC/EN 60079-31.

The terminal blocks shall be placed inside a suitable IECEX/ATEX/UKCA certified IP54 enclosure for gas atmosphere. For dust atmosphere the terminal blocks shall be mounted inside a suitable IECEX/ATEX/UKCA certified 't' enclosure (IEC/EN60079-31).

Under normal operating conditions the temperature rise of the terminal blocks is maximum 40 K, measured at the maximum permitted rated current. Due to the above mentioned, the terminal blocks may be used in apparatus of temperature classes T6..T1 as long as the terminal block ambient temperature range is not exceeded. No part of terminal block must exceed 110 °C under any condition.

T6 (- 60°C ... +40 °C)

T5 (- 60°C ... +55 °C)

T4 (- 60°C ... +70 °C)

When using the types ZDK 2.5 and ZDK 2.5 PE especially with other terminal blocks series or sizes or accessories the requirements for clearance and creepage distances according to IEC/EN 60079-7 must be observed. Regarding the use of covers, cross-connectors and end brackets the instructions of the manufacturer must be followed.

For cross connection accessories current rating, resistance across the terminal please refer to the table under "Technical data" above.

No other wire sizes or types than the ones specified in instructions must be used. The terminal blocks must either be mounted next to another block of the same type and size or with an end plate.

If smaller conductor cross sections than the rated conductor cross sections are used, then the corresponding lower current shall be stated in the Certificate of the complete apparatus.



- Cross connections with blank ends shall not be used.
- Manually cut cross connections shall not be used.

Essential Health and Safety Requirements:

Concerning ESRs this Schedule verifies compliance with the Annex II of ATEX / Schedule 1 of UKCA directive and Equipment and Protective Systems Intended for Use in Potentially Explosive Atmospheres Regulations 2016 only. By placing the product on the market, the manufacturer declares compliance with other relevant Directives, and all other safety related requirements including those of Annex II / Schedule 1 of these Directives.