



CCIC Southern Electronic Product Testing (Shenzhen) Co., Ltd.

Voltage Sag Immunity Compliance Certificate

CERTIFICATE NO.: SET2014-02575, SET2014-02581, SET2014-02582, SET2014-02583,
SET2014-02584, SET2014-02585, SET2014-02580, SET2014-02586, SET2014-02587,
SET2014-02588

Product: Switching Power Supply
Model: PRO MAX 480W 48V 10A, PRO MAX 480W 24V 20A, PRO MAX 960W 48V 20A, PRO MAX 960W 24V 40A, PRO MAX 240W 48V 5A, PRO MAX 240W 24V 10A, PRO MAX 180W 24V 7.5A, PRO MAX 120W 24V 5A, PRO MAX 120W 12V 10A, PRO MAX 72W 24V 3A, PRO MAX 72W 12V 6A, PRO MAX 70W 5V 14A, PRO MAX3 480W 24V 20A, PRO MAX3 120W 24V 5A, PRO MAX3 240W 24V 10A, PRO MAX3 960W 24V 40A
Applicant: Weidmüller Interface GmbH & Co.,KG
Address: Klingenbergstraße 16 32758 Detmold Germany
Test date and location: Feb. 14. 2014, Electronic Testing Building, Shahe Road, Xili, Nanshan District, Shenzhen, 518055, P. R. China
Tested configuration: 100% load, 50/60Hz at 120/200Vac, 1-Phase 2-wire +PE
100% load, 50/60Hz at 380Vac, 3-Phase 3-wire +PE

Certification:

CCIC Southern Electronic Product Laboratory certifies that the Switching Power Supply Meets the requirements of SEMI F47-0706 for voltage sag immunity when tested according to the procedures set forth in IEC 61000-4-11.

Signed for and on behalf of

CCIC Southern Electronic Product Testing (Shenzhen) Co., Ltd.

Wu Li An, Vice Director



Date of Issue: May. 28. 2014