

# (1) EU-TYPE EXAMINATION CERTIFICATE



- (2) Equipment and Protective Systems intended for use in Potentially Explosive Atmosphere - **Directive 2014/34/EU**
- (3) EU-Type Examination Certificate Number

**TÜV 18 ATEX 8210 U**

Issue: 01

- (4) Component: **Terminals DK/EK Series**
- (5) Manufacturer: **Weidmüller Interface GmbH & Co. KG**
- (6) Address: **Klingenbergsstraße 26  
32758 Detmold, Germany**

- (7) This product and any acceptable variation thereto are specified in the schedule to this certificate and the documents therein referred to.
- (8) The TÜV Rheinland Zertifizierungsstelle für Explosionsschutz of TÜV Rheinland Industrie Service GmbH, Notified Body No. 0035 in accordance with Article 21 of the Council Directive 2014/34/EU of 26<sup>th</sup> February 2014, certifies this product which has been found to comply with the Essential Health and Safety Requirements relating to the design and construction of equipment and protective systems intended for use in potentially explosive atmosphere, given in Annex II to the Directive.

The examination and test results are recorded in the confidential report 557/Ex8210.01/18

- (9) Compliance with the Essential Health and Safety Requirements, with the exception of those listed in the schedule of this certificate, has been assessed by reference to:

**EN IEC 60079-0: 2018**

**EN IEC 60079-7: 2015 / A1: 2018**

- (10) If the sign "X" is placed after the certificate number, it indicates that the equipment is subject to special conditions for safe use specified in the schedule to this certificate.
- (11) This EU-Type Examination Certificate relates only to the design and specification for construction of the equipment or protective system. It does not cover the process for actual manufacture or supply of the equipment or protective system, for which further requirements of the directive are applicable.
- (12) The marking of the equipment shall include the following:



**II 2 GD Ex eb IIC Gb**

TÜV Rheinland Zertifizierungsstelle für Explosionsschutz

Cologne, 2021-05-27

Dipl.-Ing. Christian Mehrhoff



This EU-Type Examination Certificate without signature and stamp shall not be valid.  
This EU-Type Examination Certificate may be circulated only without alteration. Extracts or alterations are subject to approval by the  
TÜV Rheinland Industrie Service GmbH TÜV Rheinland Group Am Grauen Stein 51105 Köln  
Tel. +49 (0) 221 806-0 Fax. + 49 (0) 221 806 114

(13) Annex

(14) **EU Type Examination Certificate**  
**TÜV 18 ATEX 8210 U**

Issue: 01

(15) Description of equipment

15.1 Equipment and type:

Terminals DK/EK Series

15.2 Description / Details of Change

General product information:

The terminal of the DK/EK- series is for the connection of copper conductors in enclosures. The type of protection is increased safety, "e" - Level of Protection "eb" (EPL "Gb").

The assessment covers the following types:

DK 4\*, DK 4Q/32\*, DK 4QV/32\*, DK 4/35,\* DK 4Q/35\*, DK 4QV/35\*, EK 4

Optional accessories:

end plate	AP DK4*, AP DK4Q*
end bracket	EWK 1*, EW 35*
Terminal rail	TS 32/ acc.to IEC 60715
	TS 35/ acc.to IEC 60715
Cross-connection	Q 2 AKZ4
	Q 3 AKZ4
	Q 4 AKZ4
	Q 10 AKZ4

Technical Data:

Operating temperature:	-50°C up to +85°C
T6	-50°C up to +40 °C
T5	-50°C up to +45 °C
T4	-50°C up to +45 °C

See manufacturer's installation instructions of each single terminal type for details.

This EU Type Examination Certificate without signature and official stamp shall not be valid.  
This certificate may be circulated without alteration. Extracts or alterations are subject to approval by:  
Zertifizierungsstelle of TÜV Rheinland Industrie Service GmbH

Details of Change:

- Standard update.
- Change of manufacturers address.

(16) Test-Report No. 557/Ex8210.01/18

(17) Schedule of Limitations

1. The DK/EK-series products are suitable for use in enclosures in atmospheres with flammable gases or combustible dust. For flammable gases these enclosures must satisfy the requirements according to EN 60079-0 and EN 60079-7. For combustible dust the enclosure must satisfy the requirements according to EN 60079-0 and EN 60079-31
2. The enclosure shall be constructed to block all sun and UV light from affecting the terminal blocks. The terminal blocks shall be placed inside a suitable certified IP54 enclosure in type of protection "eb" for gas atmosphere. For dust atmosphere the terminal blocks shall be mounted inside a suitable certified enclosure (EN 60079-31) in type of protection "t".
3. Under normal operating conditions the temperature rise of the terminal blocks is maximum 40 K, measured at the maximum permitted rated current. Due to the above mentioned, the terminal blocks may be used in apparatus of temperature classes T6..T1 as long as the terminal block ambient temperature range is not exceeded. No part of terminal block must exceed 85°C under any condition.

Ambient temperature  
 T6 (- 50°C ... +40 °C)  
 T5 (- 50°C ... +45 °C)  
 T4 (- 50°C ... +45 °C)

4. When using the DK/EK-series products especially with other terminal blocks series or sizes or accessories the requirements for clearance and creepage distances according to table 1 of EN 60079-7 must be observed. Regarding the use of covers, cross-connectors and end brackets the instructions of the manufacturer must be followed.
5. For cross connection accessories current rating, resistance across the terminal please refer to the manufacturer's installation instructions.
6. No other wire sizes or types than the ones specified in instructions must be used. The terminal blocks must either be mounted next to another block of the same type and size or with an end plate.
7. If smaller conductor cross sections than the rated conductor cross sections are used, then the corresponding lower current shall be stated in the Certificate of the complete apparatus.
8. Unused terminals shall be tightened.

This EU Type Examination Certificate without signature and official stamp shall not be valid.  
 This certificate may be circulated without alteration. Extracts or alterations are subject to approval by:  
 Zertifizierungsstelle of TÜV Rheinland Industrie Service GmbH

(18) Basic Safety and Health Requirements

Covered by afore mentioned standard

TÜV Rheinland Zertifizierungsstelle für Explosionsschutz

Cologne, 2021-05-27

Dipl.-Ing. Christian Mehrhoff



This EU Type Examination Certificate without signature and official stamp shall not be valid.  
This certificate may be circulated without alteration. Extracts or alterations are subject to approval by:  
Zertifizierungsstelle of TÜV Rheinland Industrie Service GmbH