

Firmware change-log of new features and bug fixes of the u-remote field bus coupler: 2625010000 UR20-FBC-CC

Firmware Updating Information

An update of the firmware can be done via the embedded web server. A description of the firmware update can be found in the u-remote web server manual on the Weidmüller website: www.weidmueller.com.

Version: 01.08.00	Hardware Version: 01.xx.xx	Release Date: March, 2026
--------------------------	-----------------------------------	----------------------------------

Information

- Requires u-mation configurator >= 2.0.0

New Features

- WebApp: Functional extensions according to IEC 62443 and UR-E27
 - Account and User management setup is now mandatory for initial setup
 - Authorization enforcement requires a login per default
 - HTTPS communication protocol is now default
 - Roll based access control (RBAC)
 - Session timeout handling (default 15 min)
 - Audit logging capability with data export feature
 - New welcome screen with customizable system use notification
- WebApp: Simultaneous use of u-mation configurator possible

Bug Fixes

- WebApp: Fixed missing message for coupler restart after firmware multi-update

Known Issues

- After a downgrade to previous firmware versions, a power cycle for at least 30 seconds is required to make future firmware updates possible.

Version: 01.06.00	Hardware Version: 01.xx.xx	Release Date: July, 2025
--------------------------	-----------------------------------	---------------------------------

New Supported Modules

- 2819690000 - UR20-4COM-IO-LINK-V2
- 3096630000 - SAI-AU-M8-SB-8DO-2A-V2
- 3096500000 - SAI-AU-M8-SB-8DI-V2
- 3096510000 - SAI-AU-M8-SB-8DIO-V2
- 3096490000 - SAI-AU-M12-SB-8DO-2A-V2
- 3096470000 - SAI-AU-M12-SB-8DI-V2
- 3096480000 - SAI-AU-M12-SB-8DIO-V2

Version: 01.05.00	Hardware Version: 01.xx.xx	Release Date: February, 2025
--------------------------	-----------------------------------	-------------------------------------

New Features

- Improved hot swap properties - requires UR20-AUX-VSYS as last module on the station

Version: 01.04.00	Hardware Version: 01.xx.xx	Release Date: October, 2024
--------------------------	-----------------------------------	------------------------------------

New Supported Modules

- 2920830000 - UR20-3EM-400V-AC-CT1A
- 2920840000 - UR20-3EM-400V-AC-CT5A
- 2920850000 - UR20-3EM-400V-AC-RC
- 2920860000 - UR20-3EM-400V-AC-333MV
- 2489840000 - UR20-1COM-CAN

Bug Fixes

- Fixed wrong message id in SLMP response for pull and plug alarms
- Input process data set to "0" for applications with power feed modules in case the module is powered off
- WebApp: Fixed display of substitute values for UR20-2PWM-I-2.5A-2DI-P

Version: 01.03.00	Hardware Version: 01.xx.xx	Release Date: November, 2023
--------------------------	-----------------------------------	-------------------------------------

New Supported Modules

- 2489840000 - UR20-1COM-CANOPEN

Version: 01.02.00	Hardware Version: 01.xx.xx	Release Date: August, 2022
--------------------------	-----------------------------------	-----------------------------------

New Supported Modules

- 2697910000 - UR20-2PWM-I-2.5A-2DI-P

Version: 01.01.00	Hardware Version: 01.xx.xx	Release Date: April, 2022
--------------------------	-----------------------------------	----------------------------------

New Supported Modules

- 2826800000 - UR20-1COM-232-485-422-V2

New Features

- After starting web server's Force Mode, force state of DOs can directly be set to 'off' (previously only 'on' was available)
- New file manager for import and export of multiple files in web application

Bug Fixes

- Fixed that analogue output values could become 0 when maximum value is forced via webserver
- Improved diagnostics with UR20-4COM-IO-LINK
- Fixed that after restoring default module parameters via GX Works the coupler sometimes loads previous parameter setting on reboot
- CSP+ file now limits maximum settable process data length of UR20-4COM-IO-LINK to 130 Byte
- Node ID rotary switch position now shown in web application correctly
- Web application now displays a hint when parameter changes require a restart of the coupler

Caution

- This firmware requires "u-mation Device Configurator" ≥ version 1.3.1

Version: 01.00.02	Hardware Version: 01.xx.xx	Release Date: November, 2019
--------------------------	-----------------------------------	-------------------------------------

- First released version