

TYPE APPROVAL CERTIFICATE

Certificate No:
TAE00002R0
Revision No:
1

This is to certify:

That the Terminal Block

with type designation(s)
ZSI 6 - 2

Issued to

Weidmüller Interface GmbH & Co. KG
Detmold, Germany

is found to comply with
DNV rules for classification – Ships, offshore units, and high speed and light craft

Application :

Product(s) approved by this certificate is/are accepted for installation on all vessels classed by DNV.

Issued at **Hamburg** on **2023-12-05**

This Certificate is valid until **2028-08-16**.

for **DNV**

DNV local unit: **Essen**

Approval Engineer: **Harald Amberger**

Oddvar Deinboll
Head of Section

This Certificate is subject to terms and conditions overleaf. Any significant change in design or construction may render this Certificate invalid.
The validity date relates to the Type Approval Certificate and not to the approval of equipment/systems installed.

LEGAL DISCLAIMER: Unless otherwise stated in the applicable contract with the holder of this document, or following from mandatory law, the liability of DNV AS, its parent companies and their subsidiaries as well as their officers, directors and employees ("DNV") arising from or in connection with the services rendered for the purpose of the issuance of this document or reliance thereon, whether in contract or in tort (including negligence), shall be limited to direct losses and under any circumstance be limited to 300,000 USD.



Form code: TA 251

Revision: 2022-12

www.dnv.com

Page 1 of 2

Product description

ZSI 6 -2 /FC 400V 30A 6mm² *
ZSI 6 -2/ FC LD 400V 30A 6mm² *

Tracking index CTI 600
Pollution degree 3
Over voltage category III
Terminal insulation material V0 UL 94

Application/Limitation

Location Classes:
Temperature: B, Humidity: B, Vibration: A

Requirements for fuse rating as per data sheet of the fuse manufacturer.

* The rated data depends on the type of used care fuse. Fuses have to be in compliance with DNV requirements.

Type Approval documentation

Tests carried out

IEC 60947-7-3(2002+corrigendum 2003), Cold, dry heat, damp heat, vibration and flame retardancy.

Marking of product

Weidmüller - Type designation - Main data.

Periodical assessment

The scope of the periodical assessment is to verify that the conditions stipulated for the Type approval are complied with and that no alterations are made to the product design or choice of materials.

The main elements of the assessment are:

- Inspection on factory samples, selected at random from the production line (where practicable)
- Results from Routine Tests (RT) checked (if not available tests according to RT to be carried out)
- Review of type approval documentation
- Review of possible change in design, materials and performance
- Ensuring traceability between manufacturer's product type marking and Type Approval Certificate.

Periodical assessment is to be performed after 2 years and after 3.5 years. A renewal assessment will be performed at renewal of the certificate.

END OF CERTIFICATE