

# CERTIFICATE OF COMPLIANCE

**Certificate Number** 20190913-E470829  
**Report Reference** E470829-20150730  
**Issue Date** 2019-SEPTEMBER-13

**Issued to:** Weidmueller Interface GmbH & Co. KG  
Klingenbergsstrasse 16  
32758 Detmold GERMANY

**This certificate confirms that**  
representative samples of

POWER CIRCUIT AND MOTOR-MOUNTED APPARATUS  
FOR USE IN HAZARDOUS LOCATIONS

Open-type Switch Mode Power Supplies, Cat. Nos. PRO  
DCDC 120W 24V 5A, PRO DCDC 240W 24V 10A and  
PRO DCDC 480W 24V 20A, for use in Class I, Division 2,  
Groups A, B, C and D Hazardous Locations

Have been investigated by UL in accordance with the  
Standard(s) indicated on this Certificate.

**Standard(s) for Safety:** ANSI/ISA 12.12.01, Nonincendive Electrical Equipment for  
Use in Class I and II, Division 2 and Class III, Divisions 1  
and 2 Hazardous (Classified) Locations.

CAN/CSA C22.2 No. 213-M1987, , Non-Incendive Electrical  
Equipment for Use in Class I, Div. 2 Hazardous Locations.

**Additional Information:** See the UL Online Certifications Directory at  
<https://iq.ulprospector.com> for additional information.

This Certificate of Compliance does not provide authorization to apply the UL Mark. Only the UL Follow-Up  
Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's  
Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please  
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

