

CERTIFICATE OF COMPLIANCE

Certificate Number 20190913-E470829
Report Reference E470829-20180926
Issue Date 2019-SEPTEMBER-13

Issued to: Weidmueller Interface GmbH & Co. KG
Klingenbergsstrasse 16
32758 Detmold GERMANY

This certificate confirms that
representative samples of

POWER CIRCUIT AND MOTOR-MOUNTED APPARATUS
FOR USE IN HAZARDOUS LOCATIONS

Open Type Power Supplies, Models PRO TOP1 480W 24V
20A, PRO TOP1 480W 24V 20A EX, PRO TOP1 480W 48V
10A and PRO TOP1 480W 48V 10A EX for use in Class I,
Division 2, Groups A, B, C and D Hazardous Locations

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety: UL 121201 Nonincendive Electrical Equipment for Use in
Class I and II, Division 2 and Class III, Divisions 1 and 2
Hazardous (Classified) Locations.
CSA C22.2 NO. 213 Nonincendive Electrical Equipment for
Use in Class I and II, Division 2 and Class III, Divisions 1
and 2 Hazardous (Classified) Locations.

Additional Information: See the UL Online Certifications Directory at
<https://iq.ulprospector.com> for additional information.

This *Certificate of Compliance* does not provide authorization to apply the UL Mark. Only the UL Follow-Up
Services Procedure provides authorization to apply the UL Mark.

Only those products bearing the UL Mark should be considered as being UL Certified and covered under UL's
Follow-Up Services.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Director North American Certification Program
UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at <http://ul.com/aboutul/locations/>

