

[1]

EU-TYPE EXAMINATION CERTIFICATE



[2]

**Component intended for use on/in Equipment or Protective System
Intended for use in Potentially Explosive Atmospheres
Directive 2014/34/EU**

[3] EU-Type Examination Certificate Number: **DEMKO 03 ATEX 136028U Rev. 2**[4] Component: **Earthing and Neutral Busbar assembly**[5] Manufacturer: **Weidmueller Interface GmbH & Co.**[6] Address: **Klingenbergsstraße 26, 32758 Detmold, Germany**

[7] This product and any acceptable variation thereto are specified in the schedule to this certificate and the documents therein referred to.

[8] UL International Demko A/S, notified body number 0539 in accordance with Article 17 of the Council Directive 2014/34/EU of the European Parliament and the Council, dated 26 February 2014, certifies that this component has been found to comply with the Essential Health and Safety Requirements relating to design and construction of components intended for use in potentially explosive atmospheres given in Annex II to the Directive.

The examination and test results are recorded in confidential report no. **DK/ULD/ExTR13.0005/01**.

[9] Compliance with the Essential Health and Safety Requirements has been assured by compliance with:

EN IEC 60079-0:2018

EN IEC 60079-7: 2015 +A1:2018

[10] The sign "U" is placed after the certificate number. It indicates that this certificate must not be mistaken for a certificate intended for an equipment or protective system. This partial certification may be used as a basis for certification of an equipment or protective system.

[11] This EU-Type Examination Certificate relates only to the design and construction of the specified component. Further requirements of the Directive apply to the manufacturing process and supply of this component. These are not covered by this certificate.

[12] The marking of the component shall include the following:

Ex II 2 GD Ex eb IIC Gb

Certification Manager

Jan-Erik Storgaard

This is to certify that the sample(s) of the Component described herein ("Certified Component") has been investigated and found in compliance with the Standard(s) indicated on this Certificate, in accordance with the ATEX Product Certification Program Requirements. This certificate and test results obtained apply only to the component sample(s) submitted by the Manufacturer. UL did not select the sample(s) or determine whether the sample(s) provided were representative of other manufactured component. UL has not established Follow-Up Service or other surveillance of the product. The Manufacturer is solely and fully responsible for conformity of all products to all applicable Standards, specifications, requirements or Directives. The test results may not be used, in whole or in part, in any other document without UL's prior written approval.

Date of issue: 2003-12-18

Re-issued: 2021-06-28

Notified Body

UL International Demko A/S, Ballerup 5A, 2750 Ballerup, Denmark
Tel. +45 44 85 65 65, info.dk@ul.com, www.ul.com

[13]

[14]

Schedule
EU-TYPE EXAMINATION CERTIFICATE No.
DEMKO 03 ATEX 136028U Rev. 2

[15]

Description of Component:

Earthing Busbar assembly, consisting of busbar holders type SH... or WEW..., a copper busbar and clamping yokes type ZB and WBBD 16 terminals..., for the connection of copper conductors in enclosures in type of explosion protection increased safety "e". The assembly is considered to form one component and are not to be used independently. The Ex-marking of the assembly is provided on the busbar holders. The following assembly elements are covered in this certification: rail mounting clamps type SH1, SH2, SH2S, SH3, WEW35/1 or WEW 35/2 and busbar NSCH, ESCH, SSch 10x3, SSch 12X5, SSch 6x6, SSch 15x6 and SSch 12x10

Operating temperature range -60°C ... +180°C (for ZB/NSCH without insulating material)

Operating temperature range -60°C ... +100°C (for WBBD 16 with PA66 insulating material)

Operating temperature range -60°C ... +100°C (for ZB with PA66 insulating material)

Operating temperature range -60°C ... +110°C (for SH1 and SH3 with PA66 insulating material)

Operating temperature range -60°C ... +130°C (for SH2 with KRG insulating material)

Operating temperature range -60°C ... +110°C (for WEW with Wemid insulating material)

Type**	Rated conductor cross section in mm ² (AWG)	Conductor cross section rigid in mm ² (AWG)	Conductor cross section flexible in mm ² (AWG)	Maximum current in A***	Tightening torque in Nm	Number of Conductors
NSCH	2.5 (14)	Min. 0.5 (20) Max. 2.5 (14)	Min. 0.5 (20) Max. 2.5 (14)	24 per clamping unit; 72 NSCH busbar	2	1
ZB4, ZB4K, ZB4G, ZB4/6, ZB4/6K	4 (12)	Min. 0.5 (20) Max. 6.0 (10)	Min. 0.5 (20) Max. 4.0 (12)	28*	0.5	1
ZBE6, ZBE6K	6 (10)	Min. 1.0 (20) Max. 10 (8)	Min. 1.5 (20) Max. 10 (8)	36*	1.2	1
ZB10	10 (8)	Min. 1.5 (16) Max. 10 (8)	Min. 1.5 (16) Max. 10 (8)	50*	1.2	1
ZB16 ZB16/6K, ZBE16K ZB16K, ZB16/6	16 (6)	Solid: Min. 2.5 (14) Max. 16 (6) Stranded: Min. 16 (6) Max. 25 (4)	Min. 2.5 (14) Max. 16 (6) Stranded: Min. 16 (6) Max. 25 (4)	66*	1.2	1
ZB35, ZB35K	35 (2)	-	Min. 16 (64) Max. 35 (0) Stranded: Min. 16 (6) Max. 50 (4)	109*	2.5	1
ESCH	2.5 (14)	2.5 (14)	2.5 (14)	-	2.0	1
WBBD 16****	16 (6)	Min 1.5 (20) Max 16 (6)	Stranded: Min 1.5 (20) Max 16 (6)	76A	2.5	1

Notes:

*If smaller cross sections than the rated cross section are used, the belonging lower current has to be laid down in the Certificate of the complete apparatus.

**in all colours

*** The maximum temperature was determined $\leq \Delta T$ 40 K

**** Contact Resistance WBBD 16 with rated cross section 0.42mΩ

Temperature range

Operating temperature range -60°C ... +180°C (for ZB/NSCH without insulating material)

Operating temperature range -60°C ... +100°C (for WBBD 16 with PA66 insulating material)

Operating temperature range -60°C ... +100°C (for ZB with PA66 insulating material)

Operating temperature range -60°C ... +110°C (for SH1 and SH3 with PA66 insulating material)

Operating temperature range -60°C ... +130°C (for SH2 with KRG insulating material)

Operating temperature range -60°C ... +110°C (for WEW with PA66 insulating material)

Routine tests

N/A

[13]

Schedule
EU-TYPE EXAMINATION CERTIFICATE No.
DEMKO 03 ATEX 136028U Rev. 2

[14]

Descriptive Documents

The scheduled documents are listed in the report no. provided under item no. [8] on page 1 of this EU-Type Examination Certificate.

[16]

Schedule of limitations:

The Earthing Busbar assemblies described above are considered to form one component, with Ex marking applied to the busbar holders type SH and WEW. If used independently, the above mentioned parts are not covered by this certificate.

Service temperature range -60°C ... +180°C (for ZB/NSCH/ESCH without insulating material)

Service Temperature Range -60°C ... +100°C (For WBBB 16 with PA6 insulating material)

Service temperature range -60°C ... +100°C (for ZB with PA66 insulating material)

Service temperature range -60°C ... +110°C (for SH1 and SH3 with PA66 insulating material)

Service temperature range -60°C ... +130°C (for SH2 and SH2S with KRG insulating material)

Service temperature range -60°C ... +110°C (for WEW with PA66 insulating material)

The maximum temperature rise was determined $\leq \Delta T 40$ K.

For WBBB 16 - 1 solid or stranded conductor per clamping unit

For WBBB 16 - resistance across terminal $- 0.42\text{m}\Omega$

The Earthing Busbar assemblies are suitable for use in enclosures in atmospheres with flammable gases or combustible dust. For flammable gases these enclosures must satisfy the requirements according to EN 60079-0 and EN 60079-7. For combustible dust these enclosures must satisfy the requirements according to EN 60079-0 and EN 60079-31. The enclosure shall be constructed to block all sun and UV light from affecting the terminal blocks. The terminal blocks shall be placed inside a suitable certified IP54 enclosure in type of protection "e" for gas atmosphere. For dust atmosphere the terminal blocks shall be placed inside a suitable certified IP6X enclosure in type of protection "t" for dust atmosphere

[17]

Essential Health and Safety Requirements

The Essential Health and Safety Requirements (EHSRs) covered by the standards listed at item 9.

Additional information



The trademark will be used as the company identifier on the marking label.

The manufacturer shall inform the notified body concerning all modifications to the technical documentation as described in Annex III to Directive 2014/34/EU of the European Parliament and the Council of 26 February 2014.