


IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Terminal block for copper conductors
Name and address of the applicant	Weidmüller Interface GmbH & Co. KG Klingenbergstrasse 16 / 26, 32758 Detmold Germany
Name and address of the manufacturer	Weidmüller Interface GmbH & Co. KG Klingenbergstrasse 16 / 26, 32758 Detmold Germany
Name and address of the factory	Weidmüller Interface GmbH & Co. KG Klingenbergstrasse 16 / 26, 32758 Detmold Germany
<i>Note: When more than one factory, please report on page 2</i>	<input checked="" type="checkbox"/> Additional information on page 2
Ratings and principal characteristics	Type AS.C 2.5, S.C 2.5 : Screwless-type Rated cross-section 2,5 mm ² Ui 800 V, Uimp 8 kV, Ith 24 A Type AS.C 2.5 PE, S.C 2.5 PE : Screwless-type Rated cross-section 2,5 mm ²
Trademark (if any)	
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	AS2C 2.5, AS3C 2.5, AS4C 2.5, S2C 2.5, S3C 2.5, S4C 2.5 AS2C 2.5 PE, AS3C 2.5 PE, AS4C 2.5 PE, S2C 2.5 PE, S3C 2.5 PE, S4C 2.5 PE
Additional information (if necessary may also be reported on page 2)	AS.C 2.5 and S.C 2.5 series are terminal blocks for copper conductors AS.C 2.5 PE S.C 2.5 PE series are protective conductor terminal blocks for copper conductors <input type="checkbox"/> Additional information on page 2
A sample of the product was tested and found to be in conformity with	IEC 60947-7-1:2009, IEC 60947-7-2:2009
As shown in the Test Report Ref. No. which forms part of this Certificate	2266040.50, 2266040.51

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
Arnhem, 6825 MJ
Netherlands

Date: 2022-09-20

Signature: H.R.M. Barends

IEC

IECEE

®

™

Ref. Certif. No.

NL-82433

Additional factory

EWE s.r.o.
Trebovska 570
Usti Nad Orlici, 562 03
Czech Republic

Weidmuller Lanskroun, s.r.o.
Dobrovskeho 1115
Lanskroun, 56301
Czech Republic

Weidmüller Interface (Suzhou) Co. Ltd.
No. 58 Shilin Road
215151 Suzhou Jiangsu
China

Weidmüller Interface Romania S. R. L.
Strada 66
Tautii Magheraus, 437345
Romania

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051
Arnhem, 6825 MJ
Netherlands



Date: 2022-09-20

Signature: H.R.M. Barends