

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT
(IECEE) CB SCHEME

CB TEST CERTIFICATE

| | |
|---|---|
| Product | Terminal blocks for copper conductors |
| Name and address of the applicant | Weidmüller Interface GmbH & Co. KG Klingenbergsstrae 16 32758 Detmold Germany |
| Name and address of the manufacturer | Weidmüller Interface GmbH & Co. KG Klingenbergsstrae 16 32758 Detmold Germany |
| Name and address of the factory | <input type="checkbox"/> Additional information on page 2 Weidmüller Interface GmbH & Co. KG Klingenbergsstrae 16 32758 Detmold Germany |
| Ratings and principal characteristics | 2,5 mm ² 24 A, 500 V, 6 kV (WTR 2.5...) 4 mm ² 32 A, 400 V, 6 kV (WTR 4...) 250 V (BEST/D) |
| Trademark (if any) | WEIDMÜLLER |
| Customer's Testing Facility (CTF) Stage used | |
| Model / Type Ref. | WTR 2.5, WTR 2.5 STB, WTR 2.5 + BEST/D, WTR 2.5 STB + BEST/D, WTR 4, WTR 4 STB, WTR 4 + BEST/D, WTR 4 STB + BEST/D, WTR 4 SL |
| Additional information (if necessary may also be reported on page 2) | <input type="checkbox"/> Additional information on page 2 |
| A sample of the product was tested and found to be in conformity with | IEC 60947-7-1:2009 |
| As shown in the Test Report Ref. No. which forms part of this Certificate | 2215524.50 and 2215524.51 |

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, NetherlandsThe logo for DEKRA, featuring a green right-pointing arrow followed by the word "DEKRA" in a bold, green, sans-serif font.A blue ink signature of the name "Theo Van Huet" written in a cursive, handwritten style.