

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT (IECEE) CB SCHEME

CB TEST CERTIFICATE

Product	Terminal block for copper conductors
Name and address of the applicant	Weidmüller Interface GmbH & Co. KG Klingenbergstrasse 16, 32758 Detmold Germany
Name and address of the manufacturer	Weidmüller Interface GmbH & Co. KG Klingenbergstrasse 16, 32758 Detmold Germany
Name and address of the factory	☐ Additional information on page 2 Weidmüller Interface GmbH & Co. KG Klingenbergstrasse 16, 32758 Detmold Germany
Note: When more than one factory, please report on page 2	
Ratings and principal characteristics	10 mm², 800 V, 8 kV, 57 A
Trademark (if any)	WEIDMÜLLER
Customer's Testing Facility (CTF) Stage used	
Model / Type Ref.	WDK 10
Additional information (if necessary may also be reported on page 2)	☐ Additional information on page 2 -
A sample of the product was tested and found to be in conformity with	IEC 60947-7-1:2009
As shown in the Test Report Ref. No. which forms part of this Certificate	2215547.55

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.
Meander 1051, NL-6825 MJ Arnhem, Netherlands


