



Lloyd's
Register

Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

This certificate is issued to:

PRODUCER Weidmüller Interface GmbH & Co. KG
Klingenbergsstraße 16
32758 Detmold
Germany

DESCRIPTION Stainless steel and mild steel enclosures

TYPES Klippon STB 1 SS & E
Klippon STB 1.1 SS & E
Klippon STB 2 SS & E
Klippon STB 2.1 SS & E
Klippon STB 3 SS & E
Klippon STB 4 SS & E
Klippon STB 5 SS & E
Klippon STB 6 SS & E

Klippon STB 1 MS HT
Klippon STB 1.1 MS HT
Klippon STB 2 MS HT
Klippon STB 2.1 MS HT
Klippon STB 3 MS HT
Klippon STB 4 MS HT
Klippon STB 5 MS HT
Klippon STB 6 MS HAT

APPLICATION Marine, offshore and industrial use

Certificate No. 08/20032 (E3)

Issue Date 30 November 2018

Expiry Date 24 June 2023



Sheet 1 of 2

Thorsten Wolff
Hamburg Technical Support Office
Lloyd's Register EMEA

Lloyd's Register EMEA
71 Fenchurch Street, London EC3M 4BS

Lloyd's Register EMEA
Is a subsidiary of Lloyd's Register Group

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.



Lloyd's
Register

ADDITIONAL TESTS

Type Klippon STB x SS: degree of protection IP66/67 (IEC 60529)
Type Klippon STB x MS HT: degree of protection IP66 (IEC 60529)

SPECIFIED STANDARD

DIN EN 62208 (06-2012)

RATINGS

Type	Width	Height	Depth
Klippon STB 1	120 mm	120 mm	80 mm
Klippon STB 1.1	150 mm	120 mm	80 mm
Klippon STB 2	150 mm	150 mm	90 mm
Klippon STB 2.2	190 mm	150 mm	90 mm
Klippon STB 3	190 mm	190 mm	100 mm
Klippon STB 4	250 mm	250 mm	120 mm
Klippon STB 5	380 mm	160 mm	120 mm
Klippon STB 6	400 mm	250 mm	130 mm

Intermediate sizes of identically constructed enclosures are possible.

OTHER CONDITION

Ratings for application of stainless steel enclosure type Klippon STB x SS in hazardous areas are to be obtained from Ex-Certificate No. IBExU07ATEX1148.

PLACE OF PRODUCTION

Belma Accessories Systems Sp. z o.o.
ul. Lochowska 69
85-395 Bydgoszcz
Poland

The Type Approval does not eliminate the need for normal inspection and survey procedures required by the Rules and Regulations.

If the specified standards are amended during the validity of this certificate, the product is to be re-approved prior to it being supplied to vessels to which the amended standards apply.

The Design Appraisal Document No. HTS/ETS 37588-18 and its supplementary Type Approval Terms and Conditions form part of this Certificate.

Certificate No.

08/20032 (E3)

Issue Date

30 November 2018

Expiry Date

24 June 2023

Sheet

2 of 2

Lloyd's Register EMEA
71 Fenchurch Street, London EC3M 4BS



Thorsten Wolff
Hamburg Technical Support Office
Lloyd's Register EMEA

Lloyd's Register EMEA
Is a subsidiary of Lloyd's Register Group

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as the 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.