



SWITCHING POWER SUPPLIES

BKE a.s.
U výzkumu 603
664 62 Hrušovany u Brna
Czech republic

EU DECLARATION OF CONFORMITY

The following products have been tested by us and we declare under our sole responsibility that all products carrying the CE-mark are in conformity with the provision of the Low Voltage Directive (LVD) 2014/35/EU and EMC 2014/30/EU of the European Communities.
Conformity with the directive is presumed by conformity with the following harmonized standards:

Safety EN/IEC 62477-1:2012
EMC EN 61000-4-2:2009, criterion B, kond. +/-4 kV, air +/-8 kV
EN 61000-4-3:2006, criterion A, 80-1000MHz 10V/m AM80%, 900MHz/200Hz 10V/m
50%
EN 61000-4-4:2012, criterion B, input only +/-2 kV 5/50ns
EN 61000-4-5:2014, criterion B, input only, 5,2 kV line to line, 5,2 kV line to case
EN 61000-4-6:2014, criterion A, input only, 0,15-80MHz 10V/m 80%, (9-150kHz 20V/m)
EN 55011:2009, class A

CE marked: 16

Applicant: **BKE a.s.**


Address: **U Výzkumu 603, 664 62 Hrušovany u Brna, Czech republic**

Series: **TRANSCLINIC BKE 1k5.4**

Responsibility person:

Ing. Jiří Raputa, managing director

Hrušovany u Brna, 6th of June, 2016

Signature:



Phone.: +420 547 236 111, Fax: +420 547 236 112, E-mail: bke@bke.cz, www.bke.cz