

CERTIFICATE

DEKRA

Issued to:

Applicant:
Weidmüller Interface GmbH & Co. KG
Klingenbergsstrasse 16
32758 Detmold, Germany

Licensee:
Weidmüller Interface GmbH & Co. KG
Klingenbergsstrasse 16
32758 Detmold, Germany

Product : Terminal block for copper conductors
Trade name(s) : Weidmüller
Type(s)/model(s) : ALO 6

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60947-7-1:2009
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 900119


DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 21 March 2019 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-100067

DEKRA Certification B.V.



B.T.M. Holtus
Managing Director



A.C. Slingerland
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: Terminal block for copper conductors
Trade name(s)	: Weidmüller
Type(s)/model(s)	: ALO 6
Material	: Wemid
Rated insulation voltage	: 800 V
Rated impulse withstand voltage	: 8 kV
Conventional free air thermal current	: 41 A
Rated cross-section	: 6 mm ²
Rated connecting capacity	: 0,5 mm ² - 6 mm ² rigid or flexible
Method of mounting	: top hat rail 35 mm
Description	: terminal block with screwless-type clamping units, 1-pole, with 1 clamping unit per pole, to be used in combination with cross-bridge to adjacent terminal block

TESTS**Test requirements**

EN 60947-7-1:2009

Test result

The test results are laid down in DEKRA test file 219845700.

Conclusion

The examination proved that all requirements were met.

Factory location

Weidmüller Interface GmbH & Co. KG
Klingenbergrasse 16
32758 Detmold, Germany