



Product Service

Attestation of Conformity

No. E8A 033299 0437 Rev. 00


Holder of Certificate: **Weidmüller Interface GmbH & Co. KG**
Klingenbergstr. 16
32758 Detmold
GERMANY

Name of Object: **Switching power supply unit**
(Switching Power Supply)

This Attestation of Conformity is issued on a voluntary basis according to the Directive 2014/30/EU relating to electromagnetic compatibility. It confirms that the listed apparatus complies with all essential requirements of the directive and is based on the technical specifications applicable at the time of issuance. It refers only to the particular sample submitted for testing and certification. See also notes overleaf.

Test report no.: 6876018050601

Date, 2018-12-13


(Paul Yu)

Page 1 of 2

After preparation of the necessary technical documentation as well as the EU Declaration of conformity the required CE marking can be affixed on the product. That Declaration of conformity is issued under the sole responsibility of the manufacturer. Other relevant EU-directives have to be observed.

TÜV SÜD Product Service GmbH • Certification Body • Ridlerstraße 65 • 80339 Munich • Germany

TÜV®



Product Service

Attestation of Conformity

No. E8A 033299 0437 Rev. 00

Model(s):

PRO TOP3 960W 24V 40A,
PRO TOP3 960W 24V 40A CO,
PRO TOP3 960W 48V 20A,
PRO TOP3 960W 48V 20A CO,
PRO TOP3 960W 36V 6.6A,
PRO TOP3 960W 36V 26.6A CO

Description of Object:

Rated Input: 3 x 400-500VAC, 50/60Hz, 3 x 3.4-3.2A
Rated Output: 24VDC, 40A
(for models: PRO TOP3 960W 24V 40A,
PRO TOP3 960W 24V 40A CO);
36VDC, 26.6A
(for models: PRO TOP3 960W 36V 26.6A,
PRO TOP3 960W 36V 26.6A CO);
48VDC, 20A
(for models: PRO TOP3 960W 48V 20A,
PRO TOP3 960W 48V 20A CO)

Tested according to:

EN 55032:2015
EN 55032:2012
EN 55024:2010/A1:2015
EN 55024:2010
EN 55035:2017
EN 61000-6-1:2007
EN 61000-6-2:2005
EN 61000-6-3:2007/A1:2011
EN 61000-6-4:2007/A1:2011
EN 61000-3-2:2014
EN 61000-3-3:2013