

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

## CB TEST CERTIFICATE

## Product

Fuse terminal blocks for copper conductors

## Name and address of the applicant

Weidmüller Interface GmbH & Co. KG  
Klingenbergstrasse 16 / 26,  
32758 Detmold  
Germany

## Name and address of the manufacturer

Weidmüller Interface GmbH & Co. KG  
Klingenbergstrasse 16 / 26,  
32758 Detmold  
Germany

## Name and address of the factory

Note: When more than one factory, please report on page 2

☒ Additional information on page 2Weidmüller Interface GmbH & Co. KG  
Klingenbergstrasse 16 / 26,  
32758 Detmold  
Germany

## Ratings and principal characteristics

Basic part terminal block: 250 V, 4 mm<sup>2</sup>, 6,3 A, 4 kV

Fuse holder: 6,3 A, 4 kV

size: 5x20 mm

Exclusive short circuit protection (Pvk)

separate 4,0 W / 6,3 A

compound 2,5 W / 6,3 A

Overload and short-circuit protection (Pv)

separate 1,6 W / 6,3 A

compound 1,6 W / 6,3 A

AFS 4 2C BK 10-36V BK: 10 V - 36 V

AFS 4 2C BK 30-70V BK: 30 V - 70 V

AFS 4 2C BK 60-150V BK: 60 V - 150 V

AFS 4 2C BK 100-250V BK: 100 V - 250 V

## Trademark (if any)


Weidmüller

## Customer's Testing Facility (CTF) Stage used

## Model / Type Ref.

AFS 4 2C BK,  
AFS 4 2C BK 10-36V BK,  
AFS 4 2C BK 30-70V BK,  
AFS 4 2C BK 60-150V BK,  
AFS 4 2C BK 100-250V BK

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands

IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME

Additional information (if necessary may also be reported on page 2)

A sample of the product was tested and found to be in conformity with

As shown in the Test Report Ref. No. which forms part of this Certificate


☐ Additional information on page 2

IEC 60947-7-3:2009

2248671.50

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.  
Meander 1051, NL-6825 MJ Arnhem, Netherlands



**IEC SYSTEM FOR MUTUAL RECOGNITION OF TEST CERTIFICATES FOR ELECTRICAL EQUIPMENT  
(IECEE) CB SCHEME****Additional factory**

Weidmüller Interface Romania S. R. L

Strada 66

437345 Tautii Magheraus

Romania

EWE s.r.o.

Trebovska 570

562 03 Usti Nad Orlici,

Czech Republic

Weidmüller Interface (Suzhou) Co. Ltd.

No. 58 Shilin Road

215151 Suzhou

China

Weidmuller Lanskroun, s.r.o.

Dobrovskeho 1115

56301 Lanskroun

Czech Republic

This CB Test Certificate is issued by the National Certification Body

DEKRA Certification B.V.

Meander 1051, NL-6825 MJ Arnhem, Netherlands

