

CERTIFICATE OF COMPLIANCE

Certificate Number 20141114-E470829
Report Reference E470829-20141115
Issue Date 2014-NOVEMBER-14

Issued to: Weidmueller Interface GmbH & Co Kg
KLINGENBERGSTR 16
32758 DETMOLD GERMANY

**This is to certify that
representative samples of**

POWER CIRCUIT AND MOTOR-MOUNTED APPARATUS
FOR USE IN HAZARDOUS

Class I, Division 2, Groups A, B, C and D Hazardous
Locations

Switching Power Supplies, Models PRO MAX 480W 24V
20A and PRO MAX 480W 48V 10A

Have been investigated by UL in accordance with the
Standard(s) indicated on this Certificate.

Standard(s) for Safety:

ANSI/ISA 12.12.01, Nonincendive Electrical Equipment for
Use in Class I and II, Division 2 and Class III, Divisions 1
and 2 Hazardous (Classified) Locations;
CAN/CSA C22.2 No. 213-M1987, Non-Incendive Electrical
Equipment for Use in Class I, Division 2 Hazardous
Locations.

Additional Information:

See the UL Online Certifications Directory at
www.ul.com/database for additional information

Only those products bearing the UL Certification Mark should be considered as being covered by UL's
Certification and Follow-Up Service.

Look for the UL Certification Mark on the product.



Bruce Mahrenholz, Assistant Chief Engineer, Global Inspection and Field Services

UL LLC

Any information and documentation involving UL Mark services are provided on behalf of UL LLC (UL) or any authorized licensee of UL. For questions, please
contact a local UL Customer Service Representative at www.ul.com/contactus

