

Type Approval Certificate

This is to certify that the undernoted product(s) has/have been tested with satisfactory results in accordance with the relevant requirements of the Lloyd's Register Type Approval System.

Manufacturer **Weidmueller Interface GmbH & Co. KG**

Address Klingenbergsstr. 26, Detmold, 32758, Germany

Place of Production Weidmüller Interface (Suzhou) Co. Ltd.

58 ShiLin Road, SND Suzhou, Suzhou, Jiangsu Province, 215151, China

Place of Production Weidmüller Interface GmbH & Co. KG

Klingenbergstrasse 16, Detmold, 32758, Germany

Type Terminals/Insulators

Description Sectional terminal blocks for rail mounting with recessed connectors.

Trade Name SAKD, SAK and DK

Application Marine, offshore and industrial applications for use in environmental categories ENV1, ENV2, ENV3 and ENV4 as defined in LR Type Approval System, Test Specification No. 1 - 2002.

Specified Standard IEC 60947-7-1: 2009-04

Thorsten Wolff

Senior Specialist to Lloyd's Register EMEA
A member of the Lloyd's Register group

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.

Type Approval Certificate

Ratings	Type	Voltage	Continuous Current	Maximum mm ²	Conductor Size AWG
SAKD 2.5N	SAKD 2.5N	500V	24A	2.5	14
SAK 2.5	SAK 2.5/35	800/1000V	24 to 192A	2.5 to 70	14 to 00
SAK 4	SAK 4/35				
SAK 6N	SAK 6/35				
SAK 10	SAK 10/35				
SAK 16	SAK 16/35				
SAK 35	SAK 35/35				
SAK 70					
DK 4		500V	26A	4	12

This certificate is not valid for equipment, the design, ratings or operating parameters of which have been varied from the specimen tested. The manufacturer should notify Lloyd's Register EMEA of any modification or changes to the equipment in order to obtain a valid Certificate.

Previous Version: 91/20228 (E7)

The Design Appraisal Document HPC1762112-22/TW and its supplementary Type Approval Terms and Conditions form part of this Certificate.

71 Fenchurch Street, London, EC3M 4BS, United Kingdom

Lloyd's Register Group Limited, its affiliates and subsidiaries and their respective officers, employees or agents are, individually and collectively, referred to in this clause as 'Lloyd's Register'. Lloyd's Register assumes no responsibility and shall not be liable to any person for any loss, damage or expense caused by reliance on the information or advice in this document or howsoever provided, unless that person has signed a contract with the relevant Lloyd's Register entity for the provision of this information or advice and in that case any responsibility or liability is exclusively on the terms and conditions set out in that contract.