

CERTIFICATE

Issued to:
Applicant:
Weidmüller Interface GmbH & Co. KG
Klingenbergstrasse 16
32758 Detmold, Germany

Licensee:
Weidmüller Interface GmbH & Co. KG
Klingenbergstrasse 16
32758 Detmold, Germany

Product : Terminal blocks for copper conductors
Trade name(s) : Weidmüller
Type(s)/model(s) : SAKK 10, SAKK 10 KER/WS, SAKK 4 and SAKK 4 KER/WS

The product and any acceptable variation thereto is specified in the Annex to this certificate and the documents therein referred to.

DEKRA hereby declares that the above-mentioned product has been certified on the basis of:

- a type test according to the standard EN 60947-7-1:2009
- an inspection of the production location according to CENELEC Operational Document CIG 021
- a certification agreement with the number 900119

DEKRA hereby grants the right to use the KEMA-KEUR certification mark.

The KEMA-KEUR certification mark may be applied to the product as specified in this certificate for the duration of the KEMA-KEUR certification agreement and under the conditions of the KEMA-KEUR certification agreement.

This certificate is issued on 20 November 2018 and expires upon withdrawal of one of the above mentioned standards.

Certificate number: 71-105513

DEKRA Certification B.V.



drs. G.J. Zoetbrood
Managing Director



Kate Xu
Certification Manager

© Integral publication of this certificate is allowed

ACCREDITED BY THE
DUTCH ACCREDITATION
COUNCIL



SPECIFICATION OF THE CERTIFIED PRODUCT**Product data**

Product	: Terminal blocks for copper conductors
Trade name(s)	: Weidmüller
Type(s)/model(s)	: SAKK 10, SAKK 10 KER/WS, SAKK 4 and SAKK 4 KER/WS
Rated insulation voltage	: 800 V
Rated impulse withstand voltage	: 8 kV
Mounting rail	: G-type rail 32 mm
Pollution degree	: 3

Product data – type SAKK 10

Conventional free air thermal current	: 57 A
Rated cross section	: 10 mm ²
Rated connecting capacity	: 1,5 mm ² - 16 mm ² rigid 1,5 mm ² - 10 mm ² flexible
Torque level	: 1,2 Nm
Stripping length	: 12 mm
Description	: terminal block with screw-type clamping units, 1-pole, two clamping units per pole

Product data – type SAKK 10 KER/WS

Conventional free air thermal current	: 57 A
Rated cross section	: 10 mm ²
Rated connecting capacity	: 1,5 mm ² - 16 mm ² rigid 1,5 mm ² - 10 mm ² flexible
Torque level	: 1,2 Nm
Stripping length	: 12 mm
Description	: terminal block with screw-type clamping units, 1-pole, two clamping units per pole

Product data – type SAKK 4

Conventional free air thermal current	: 32 A
Rated cross section	: 4 mm ²
Rated connecting capacity	: 0,5 mm ² - 6 mm ² rigid 0,5 mm ² - 4 mm ² flexible
Torque level	: 0,5 Nm
Stripping length	: 10 mm
Description	: terminal block with screw-type clamping units, 1-pole, two clamping units per pole

Product data – type SAKK 4 KER/WS

Conventional free air thermal current	: 32 A
Rated cross section	: 4 mm ²
Rated connecting capacity	: 0,5 mm ² - 6 mm ² rigid 0,5 mm ² - 4 mm ² flexible
Torque level	: 0,5 Nm
Stripping length	: 10 mm
Description	: terminal block with screw-type clamping units, 1-pole, two clamping units per pole

TESTS

Test requirements

EN 60947-7-1:2009

Test result

The test results are laid down in DEKRA test file 222855600.

Conclusion

The examination proved that all requirements were met.

Factory location

Weidmüller Interface GmbH & Co. KG
Klingenbergstrasse 16
32758 Detmold, Germany