



# IECEx Certificate of Conformity

## INTERNATIONAL ELECTROTECHNICAL COMMISSION IEC Certification System for Explosive Atmospheres

for rules and details of the IECEx Scheme visit [www.iecex.com](http://www.iecex.com)

### Ex COMPONENT CERTIFICATE

Certificate No.:	<b>IECEx DEK 21.0033U</b>	Page 1 of 3	<a href="#">Certificate history</a> :
Status:	<b>Current</b>	Issue No: 0	
Date of Issue:	2021-11-15		
Applicant:	<b>Weidmuller Interface GmbH &amp; Co. KG</b> Klingenbergsstrasse 16 32758 Detmold Germany		
Ex Component:	Terminal Block Type WDU 240		

*This component is NOT intended to be used alone and requires additional consideration when incorporated into other equipment or systems for use in explosive atmospheres (refer to IEC 60079-0).*

Type of Protection: **Ex e**

Marking: **Ex eb IIC Gb**

Approved for issue on behalf of the IECEx  
Certification Body:

**L.G. van Schie**

**Certification Manager**

Position:

Signature:  
(for printed version)

Date:

2021-11-15

1. This certificate and schedule may only be reproduced in full.
2. This certificate is not transferable and remains the property of the issuing body.
3. The Status and authenticity of this certificate may be verified by visiting [www.iecex.com](http://www.iecex.com) or use of this QR Code.



Certificate issued by:

**DEKRA Certification B.V.**  
Meander 1051  
6825 MJ Arnhem  
Netherlands





# IECEx Certificate of Conformity

Certificate No.: **IECEx DEK 21.0033U**

Page 2 of 3

Date of issue: 2021-11-15

Issue No: 0

Manufacturer: **Weidmuller Interface GmbH & Co. KG**  
Klingenbergsstrasse 16  
32758 Detmold  
Germany

Additional  
manufacturing  
locations:

This certificate is issued as verification that a sample(s), representative of production, was assessed and tested and found to comply with the IEC Standard list below and that the manufacturer's quality system, relating to the Ex products covered by this certificate, was assessed and found to comply with the IECEx Quality system requirements. This certificate is granted subject to the conditions as set out in IECEx Scheme Rules, IECEx 02 and Operational Documents as amended

## STANDARDS :

The equipment and any acceptable variations to it specified in the schedule of this certificate and the identified documents, was found to comply with the following standards

**IEC 60079-0:2017** Explosive atmospheres - Part 0: Equipment - General requirements  
Edition:7.0

**IEC 60079-7:2017** Explosive atmospheres - Part 7: Equipment protection by increased safety "e"  
Edition:5.1

This Certificate **does not** indicate compliance with safety and performance requirements  
other than those expressly included in the Standards listed above.

## TEST & ASSESSMENT REPORTS:

A sample(s) of the equipment listed has successfully met the examination and test requirements as recorded in:

Test Report:

[NL/DEK/ExTR21.0030/00](#)

Quality Assessment Report:

[NL/DEK/QAR12.0052/07](#)



# IECEx Certificate of Conformity

Certificate No.: **IECEx DEK 21.0033U**

Page 3 of 3

Date of issue: 2021-11-15

Issue No: 0

**Ex Component(s) covered by this certificate is described below:**

## Description

Terminal Block Type WDU 240 with accessories, is intended for the connection of copper conductors in enclosures in type of protection increased safety "e" or dust ignition protection "t".

Fixing is made on mounting rails type TS 32 according to EN 60715-G 32 or TS 35 according to EN 60715-TH 35.

## Specifications

Operating temperature range: -50 °C to +110 °C.

Refer to Annex 1 to for the electrical data and nomenclature.

## SCHEDULE OF LIMITATIONS:

1. The Terminal Blocks shall be mounted in a certified enclosure that meets the requirements of an approved type of protection as specified in IEC 60079-0 clause 1, with a degree of protection at least as required for Ex e.
2. When assembling with other certified series and sizes and using the associated accessories, the required creepage distances and clearances have to be observed.
3. The installation instruction of the manufacturer shall be followed e.g. for the use of cover, jumpers, end brackets. The data regarding current and associated temperature rise shall be used as guideline for the given conductor cross sections. The cross section has influence on the temperature rise which shall be assessed in the end application.
4. If the Terminal Blocks are used in electrical apparatus of temperature classes T1 up to T5, the highest temperature of the insulating material shall not exceed the maximum value of the operating temperature range.
5. If the Terminal Blocks are used in electrical apparatus of temperature classes T6 the permissible ambient temperature range is  $-60^{\circ}\text{C} < T_{\text{amb}} < +40^{\circ}\text{C}$ .
6. The electrical data per Annex 1 applies.

## Annex:

<225645300-ExTR21.0030.00-Annex1.pdf>