



Certificate of Compliance

Certificate: 80109105

Master Contract: 200039

Project: 80109105

Date Issued: 2022-02-28

Issued To: Weidmueller Interface GmbH & Co. KG
Klingenbergsstrasse 16
Detmold, North Rhine-Westphalia, 32758
Germany

Attention: Jochen Reese

The products listed below are eligible to bear the CSA Mark shown

Issued by: *Jan Holtman*
Jan Holtman



PRODUCTS

CLASS - C622801 - WIRE CONNECTING DEVICES Terminal Assemblies

PCTB Terminal blocks Screw-tightening pressure type, for use with solid and stranded copper conductors.



Certificate: 80109105
Project: 80109105

Master Contract: 200039
Date Issued: 2022-02-28

Catalogue number	Voltage [V]	Group	Current [A]	Wire-Range [AWG]	Torque [Nm]	Remarks
AKE 2.5	-	B, C	-	26-12	0.4-0.6	PCTB
AKE 4	-	B, C	-	26-12	0.5-1	PCTB

Notes:

1. Certified for use in other equipment where the acceptability of the combination is to be determined in the end use.
2. The Protective Conductor Terminal Blocks (PCTB) Types: AKE 2.5 and AKE 4 are intended for use with the following mounting rail types:

Cat. No.	DIN mounting rail		
	Width by Height, mm	Thickness, mm	Material type
AKE 2.5, AKE 4	15 x 5	1	Steel

APPLICABLE REQUIREMENTS

CSA C22.2 No. 0 - 20
CSA C22.2 No. 158 - 10

- General Requirements Canadian Electrical Code, Part II
- Terminal Blocks

Notes:

Products certified under Class C622801 have been certified under CSA's ISO/IEC 17065 accreditation with the Standards Council of Canada (SCC). www.scc.ca





Supplement to Certificate of Compliance

Certificate: 80109105

Master Contract: 200039

*The products listed, including the latest revision described below,
are eligible to be marked in accordance with the referenced Certificate.*

Product Certification History

Project	Date	Description
80109105	2022-02-28	Original Certification of Cat. No's AKE 2.5 and AKE 4 to the requirements of C22.2 no. 158-10 (R2019).